

MINIMUM FIRE EXTINGUISHER REQUIREMENTS

Group and Div	Min. #	Class of extinguisher	Max. distance	Floor Area Per unit {Max}
A-1, A-2, A-2.1, A-3, A-4	2	2A-10BC	100'	1500 Sq ft.
B	1	2A-10BC	100'	1500 Sq ft.
E-1, E-2, E-3	See UFC standard 10-1			
F-1, F-2	1	2A-10BC	100'	1500 Sq Ft.
H-1, H-2, H-3, H-4, H-5, H-6, H-7	See UFC standard 10-1			
I-1.1, I-1.2, I-2, I-3	See UFC standard 10-1			
M	1	2A-10BC	100'	1500 Sq Ft.
R-1 *	1	2A-10BC	100'	3000 Sq Ft.
R-2.1 * , R-2.2 * , R-2.1.1 *	1	2A-10 BC	75'	3000 Sq Ft.
R-2.2.1 * R-2.3 * , R-2.3.1 *	1	2A-10BC	75'	3000 Sq Ft.
R-3 *	No Requirement			
S-1, S-2, S-3, S-4, S-5	1	2A-10BC	100'	1500 Sq Ft.
U-1, U-2	No Requirement			

Outdoor carnivals & fairs **	1	2A-10BC	75'
Outdoor concession stand deep fat fryers	1	Class K	30'
Tents and Canopies **	1	2A-10BC	75'
Cooking, other than deep fat frying	1	40-BC or Class K	30'
Wood burning products	1	4-A 60 BC	30'
Fuel dispensing area ***	1	2A-20BC	75'
Asphalt kettles ****	1	4A-20BC	30'
Battery chargers	1	4A-20BC	20'
Motorized floats	1	2A-10BC	each

* Smoke Detectors Required

** If Deep fat frying type K extinguisher required

*** 1 Per island

**** Also one on roof {100' max } 2A-20BC

Must be mounted in plain view, not higher than 48" off floor.

Should be mounted at or near the exit doors.

All fire extinguishers must have current State Certification.